

Solicitation No. - N° de l'invitation

E0224-130609/A

Client Ref. No. - N° de réf. du client

R.001718.003

Amd. No. - N° de la modif.

002

File No. - N° du dossier

PWD-2-35037

Buyer ID - Id de l'acheteur

pwd004

CCC No./N° CCC - FMS No./N° VME

THE FOLLOWING AMENDMENT TO THE BID DOCUMENTS IS EFFECTIVE
IMMEDIATELY. THE ADDENDUM SHALL FORM PART OF THE CONTRACT
DOCUMENTS.

DRAWINGS:

With respect to Drawing A201, Keynote 4, and reference to “rigid metal braces installed in the ceiling area in a 2 metre grid pattern”, the intent is to provide rigid metal braces to resist wind-uplift of the suspended ceiling. Acceptable rigid metal bracing material include but is not limited to galvanized light-weight metal stud framing.

All other terms & conditions remain unchanged.