

**RETURN BIDS TO:**  
**RETOURNER LES SOUMISSIONS À:**  
Public Works and Government Services Canada  
Telus Plaza North/Plaza Telus Nord  
10025 Jasper Ave./10025 ave. Jaspe  
5th floor/5e étage  
Edmonton  
Alberta  
T5J 1S6  
Bid Fax: (780) 497-3510

**SOLICITATION AMENDMENT**  
**MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address  
Raison sociale et adresse du  
fournisseur/de l'entrepreneur

**Issuing Office - Bureau de distribution**  
Public Works and Government Services Canada  
Telus Plaza North/Plaza Telus Nord  
10025 Jasper Ave./10025 ave Jasper  
5th floor/5e étage  
Edmonton  
Alberta  
T5J 1S6

<b>Title - Sujet</b> Dish Room Revital. - Grande Cache	
<b>Solicitation No. - N° de l'invitation</b> EW038-141677/A	<b>Amendment No. - N° modif.</b> 003
<b>Client Reference No. - N° de référence du client</b> CSC	<b>Date</b> 2014-01-17
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$PWU-201-10034	
<b>File No. - N° de dossier</b> PWU-3-36252 (201)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin</b> <b>at - à 02:00 PM</b> <b>on - le 2014-01-24</b>	
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input checked="" type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Ho (RPC), Hector	<b>Buyer Id - Id de l'acheteur</b> pww201
<b>Telephone No. - N° de téléphone</b> (780) 497-3543 ( )	<b>FAX No. - N° de FAX</b> (780) 497-3510
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b>	

Instructions: See Herein

Instructions: Voir aux présentes

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm</b> <b>(type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/</b> <b>de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

**This amendment has been raised to make the following changes:**

**On Page 1 of 12, under section Solicitation Closes**

**DELETE:**

2014-01-21

**INSERT:**

2014-01-24

**Question 1:**

On mechanical drawing M2, on the dish was room plumbing demolition plan, there is some hatched plumbing mainly notes 6 and 8 that is says must be removed. I was wondering if that plumbing was above the slab or in the slab.

**Answer 1:**

It is above the slab. Please see attached photos.

**Question 2:**

I was wondering if we are allowed to have a computer in our work trailer or if no communication devices are allowed in the facility at all.

**Answer 2:**

No computers or phones or any communication devices allowed inside the institution.

**Question 3:**

Can you please release the information for the temporary wash trailer to be used for this project?

**Answer 3:**

Please see attached document

**All other Terms and Conditions remain unchanged**

**Part 1            General**

**1.1                ACTION AND INFORMATIONAL SUBMITTALS**

- .1            Provide submittals in accordance with Section 01 33 00 - Submittal Procedures.

**1.2                INSTALLATION AND REMOVAL**

- .1            Prepare site plan indicating proposed location and dimensions of area where trailer is to be installed, avenues of ingress/egress to trailer and adjacent areas.
- .2            Indicate use of supplemental or other staging area.
- .3            Provide construction facilities in order to execute work expeditiously.
- .4            Remove from site all such work after use.
- .5            Provide all services connections as required for full operation.
- .6            Provide secure installation of all fittings and accessories.
- .7            After use, remove from site all services connections and repair any areas affected by installation.

**Part 2            Products**

**2.1                TEMPORARY DISHWASHER TRAILER**

- .1            Equipment: Ecotemp Work Horse WH-44 high temperature conveyor dishwasher with booster heater, three 610mm x 1829mm stainless steel work tables, three compartment sink, hand wash sink, tankless 'on demand' hot water system.
- .2            Trailer: Two 5000 watt wall heaters, fire exit lights, vapour sealed flourescent lighting, insulated floor, walls, and ceiling.
- .3            Connections: 200 amp three phase 220 volt, 19mm food grade fresh water line, 76mm grey water disposal line, standard propane hook-up.

**Part 3            Execution**

**3.1                TRAILER INSTALLATION**

- .1            Confirm installation location with user to allow for unimpeded work flow to adjacent areas. Install trailer to manufacturers recommendations. Ensure trailer is solidly braced and service connections are secure.
- .2            Ensure that all equipment is fully operational. Provide training to user for correct operation of equipment.

**END OF SECTION**