

RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Bid Receiving Public Works & Government Services
Canada/Réception des soumissions Travaux publics et
Services gouvernementaux Canada
1713 Bedford Row
Halifax, N.S./Halifax,(N.E.)
B3J 1T3
Halifax
Bid Fax: (902) 496-5016

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
**Raison sociale et adresse du
fournisseur/de l'entrepreneur**

Issuing Office - Bureau de distribution
Real Property Contracting
1713 Bedford Row
P.O. Box 2247/C.P.2247
Halifax, N.S./Halifax, (N.E.)
B3J 3C9
Halifax

Title - Sujet INSTALL SUSPENDED CEILINGS	
Solicitation No. - N° de l'invitation E0225-142501/A	Amendment No. - N° modif. 003
Client Reference No. - N° de référence du client 20142501	Date 2014-03-13
GETS Reference No. - N° de référence de SEAG PW-\$PWA-110-5066	
File No. - N° de dossier PWA-3-70129 (110)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2014-03-17	Time Zone Fuseau horaire Atlantic Daylight Saving Time ADT
F.O.B. - F.A.B. Plant-Usine: ☐ Destination: ☒ Other-Autre: ☐	
Address Enquiries to: - Adresser toutes questions à: Collier (PWA), Susan	Buyer Id - Id de l'acheteur pwa110
Telephone No. - N° de téléphone (902) 496-5350 ()	FAX No. - N° de FAX (902) 496-5016
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Amendment 003 is being issued to answer a question from a potential bidder and provide clarification on section 00 10 10 as follows:

Question 1:

Could you confirm the height of the ductwork now. We need to know if it has to be lowered.

Answer 1:

See note on drawing MSK-MV-130. No main horizontal ventilation trunks nor horizontal branches are lowered.

Remove existing round diffuser and duct down to new diffuser at ceiling level with max 2.0 m of flex duct (typical of 6). The existing vertical spiral duct is being extended to accommodate the new ceiling height in 6 locations.

Reference Specification

Section 00 10 10 General Instructions

1.CLARIFICATION: There will be no vehicle parking available for general contractor nor sub-contractors on site. Deliveries must be co-ordinated through security.

2. Para. 1.3 Work Schedule ADD: para. 1.3.6 Work in PTSS Shop (1N1'02 thru 1N1'08) to be complete prior to start of work in Radio Workshop (1L1'02 thru 1L1'08).

Section 01 35 54 Site Security

1.CLARIFICATION: All supervision and trades working on this project ,despite their current access level, will be considered Access 2 and will require escort(s) at all times.

ALL OTHER TERMS AND CONDITIONS REMAIN THE SAME