



Parks Canada
Parcs Canada



RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:

Parks Canada Agency
National Contracting Service
Bid Receiving Unit
111 Water St. East
Cornwall ON K6H 6S3

AMENDMENT
MODIFICATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Contract remain the same

Ce document est par la présente révisé; sauf indication contraire, les modalités du contrat demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Parks Canada Agency
111 Water St. East
Cornwall ON K6H 6S3

Title-Sujet Replacement of Fuel Storage Tanks and Pumps - Ingonish		Date June 15, 2015
Solicitation No. - No. de l'invitation 5P300-15-5120	Amendment No. - No. de modif. 01	
GETS Reference No. - No de reference de SEAG		
Solicitation Closes L'invitation prend fin - at - à 02:00 PM on - le June 23, 2015	Time Zone Fuseau horaire - Eastern Daylight Time (EDT)	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input type="checkbox"/> Other-Autre: <input type="checkbox"/>		
Address Inquiries to: - Adresser toute demande de renseignements à : Céline Morin (celine.morin@pc.gc.ca)		
Telephone No. - No de téléphone 613-938-5940	Fax No. - No de FAX:	
Destination of Goods, Services, and Construction: Destinations des biens, services et construction: See Herein		
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur :		
Telephone No. - No de téléphone: _____		
Facsimile No. - N° de télécopieur: _____		
E-mail - Courriel : _____		
Name and title of person authorized to sign on behalf of the Vendor/Firm Nom et titre de la personne autorisée a signer au nom du fournisseur/ de l'entrepreneur		
_____ Name / Nom		_____ Title / Titre
_____ Signature		_____ Date

THE PURPOSE OF THIS AMENDMENT IS TO GIVE EFFECT TO THE CHANGE TO SPECIFICATIONS INDICATED IN ATTACHED ADDENDUM 1.

Please sign page 1 and return with bid.

ALL OTHER TERMS AND CONDITIONS OF THE ITT REMAIN UNCHANGED.

1 General

1.1 ADDENDUM #1

All clauses set forth in the Bidding Documents, Contract Documents and General Requirements of the original Contract Documents shall apply to and govern this work.

The addendum refers to changes and additions to the original Contract Documents and is to be read in conjunction with the same. All other parts of the original Contract Documents are to be considered as applying to the work of this Contract with the exceptions and changes as noted below.

DRAWINGS

<u>Item #1</u>	<u>Reference Drawing M1 - Mechanical & Electrical Site Plan</u>
.1	<u>Reference Detail 3:</u>
.1	<u>Delete Note:</u> "Provide access ladder & Platform 450 x 600." <u>and replace with new note to read:</u> "Provide access ladder & Platform 450 x 600. Platforms, stairs and handrails: Provide welded steel tank attachments designed to support platform framing, stairs and live and dead loadings. Provide access platform and guard rails to allow for tank fueling, level measuring and inspection. Clean and coat all surfaced with corrosion resistant paint and primer to match fuel storage tank requirements as specified. Fiberglass Reinforced Plastic (FRP) to be considered an acceptable alternate."

End of Section