

	National Defence Défense Nationale		Back to the DID List
DATA ITEM DESCRIPTION - DESCRIPTION DE DONNÉES			
1. TITLE – TITRE		2. IDENTIFICATION NUMBER - NUMÉRO D'IDENTIFICATION	
Conduct Fire Prevention and Life safety Inspection		DID 16.8	
3. DESCRIPTION / PURPOSE – DESCRIPTION / OBJET			
The purpose of conducting a Fire Prevention and Life safety Inspection is to assess the potential fire and life safety hazards in a building.			
4. APPROVAL DATE DATE D'APPROBATION	5. OFFICE OF PRIMARY INTEREST (OP) BUREAU DE PREMIERE RESPONSABILITÉ (BPR)	6. GIDEP APPLICABLE D'ÉCHANGE DE DONNÉES PERTINENT	
November 2020	North Warning System Office (NWSO)		
7. APPLICATION / INTERRELATIONSHIP – APPLICATION / INTERDÉPENDANCE			
CDRL 16.8 and SOW paragraph 16.8 to 16.8.3 refer This DID contains the format and content preparation instructions for the data generated under the work tasks described in the NWS O&M SOW.			
8. ORIGINATOR - AUTEUR		9. APPLICABLE FORMS - FORMULES PERTINENTES	
RP TA			
10. PREPARATION INSTRUCTIONS – INSTRUCTIONS SUR LA PRÉSENTATION DES DONNÉES			
<p>10.1 The Contractor must conduct Fire Prevention and Life Safety Inspections at NWS locations as follows: Semi-annually; LRR sites - annually; Sites - a minimum of 2 sites inspected annually per Zone, with different sites being visited in subsequent years until site in the Zone have been inspected; SRO - annually; NWSCC - semi-annually; and NWSSC - semi-annually.</p> <p>10.2 The Contractor must ensure that inspections include, at a minimum: An inspection of buildings to NFC classification and Fire Marshal Directive (FMD) and Fire Protection Program (FPP); Assurance of compliance, adequacy, quality and diligence of field level inspections being completed by Fire Wardens; Fire evacuation drills to ensure resources knowledge and level of training; Review the fire services plan to confirm its applicability and currency; Training to on-site resources as required; and Assessment of the fire protection facilities, and recommendations for improvements.</p> <p>10.3 The Contractor must submit Fire Prevention Inspection reports in accordance with the RPDRL and track findings not corrected at the time of the inspection to completion within six months in the WMS.</p>			