

	National Defence Défense Nationale		Back to the DID List
DATA ITEM DESCRIPTION - DESCRIPTION DE DONNÉES			
1. TITLE – TITRE		2. IDENTIFICATION NUMBER - NUMÉRO D'IDENTIFICATION	
Conduct Portable Fire Extinguisher Training (PFET)		DID 16.5	
3. DESCRIPTION / PURPOSE – DESCRIPTION / OBJET			
The purpose of conducting PFET for all personnel is to train and promote confidence in a users ability to extinguish a fire as early as possible			
4. APPROVAL DATE DATE D'APPROBATION	5. OFFICE OF PRIMARY INTEREST (OP) BUREAU DE PREMIERE RESPONSABILITÉ (BPR)	6. GIDEP APPLICABLE D'ÉCHANGE DE DONNÉES PERTINENT	
November 2020	North Warning System Office (NWSO)		
7. APPLICATION / INTERRELATIONSHIP – APPLICATION / INTERDÉPENDANCE			
CDRL 16.5 and SOW paragraph 16.5.1 refer This DID contains the format and content preparation instructions for the data generated under the work tasks described in the NWS O&M SOW.			
8. ORIGINATOR - AUTEUR		9. APPLICABLE FORMS - FORMULES PERTINENTES	
RP TA			
10. PREPARATION INSTRUCTIONS – INSTRUCTIONS SUR LA PRÉSENTATION DES DONNÉES			
<p>10.1 Training to be recorded in the daily log book. Individual names are to be recorded separately and kept on file for 3 years. Items to be covered in PFET include but are not limited to: action upon discovery of fire, action in the event of fire, types of extinguishers and effective extinguishment.</p> <p>10.2 LSS staff who are not part of the fire brigade, Contractor personnel who occasionally visit LSSs, LRR sites and/or SRR sites and temporary hires who will be working and living on NWS sites are to receive Portable Fire Extinguisher Training (PFET), and are to be instructed on fire safety in their areas of responsibility.</p> <p>10.3 Employees who are in this category shall receive PFET within 24 hours of arriving on a site, and PFET training shall be regenerative on a 4 year cycle. Employees shall receive a training certificate/card upon completion of the training.</p> <p>10.4 New permanent employees to receive PFET training within 30 days of being hired.</p>			