

	National Defence Défense Nationale		Back to the DID List
DATA ITEM DESCRIPTION - DESCRIPTION DE DONNÉES			
1. TITLE – TITRE		2. IDENTIFICATION NUMBER - NUMÉRO D'IDENTIFICATION	
Maintain a Log of Fire Alarm and Fire Protection system Malfunction Alarms		DID 16.12	
3. DESCRIPTION / PURPOSE – DESCRIPTION / OBJET			
The purpose is to have data on problematic systems and parts.			
4. APPROVAL DATE DATE D'APPROBATION	5. OFFICE OF PRIMARY INTEREST (OP) BUREAU DE PREMIERE RESPONSABILITÉ (BPR)	6. GIDEP APPLICABLE D'ÉCHANGE DE DONNÉES PERTINENT	
TBD	North Warning System Office (NWSO)		
7. APPLICATION / INTERRELATIONSHIP – APPLICATION / INTERDÉPENDANCE			
CDRL 16.12 and SOW paragraph 16.12.6 refer This DID contains the format and content preparation instructions for the data generated under the Work tasks described in the NWS O&M SOW.			
8. ORIGINATOR - AUTEUR		9. APPLICABLE FORMS - FORMULES PERTINENTES	
RP TA			
10. PREPARATION INSTRUCTIONS – INSTRUCTIONS SUR LA PRÉSENTATION DES DONNÉES			
10.1 The Contractor must maintain a log of fire alarms and fire protection system malfunction alarms, including at a minimum: 10.2 The name of the individual making the entry, 10.3 The site, date, time, alarm details, 10.4 Immediate actions taken upon receipt of the alarm, and 10.5 The ESR or Work Order opened to track the alarm, and the time the log entry was completed. 10.6 The Contractor must complete the entry for each alarm event within 12 hours after occurrence, and provide the RP-TA with a copy of the log upon request within two business days.			