




ENGINEERS - PROJECT MANAGEMENT
902.566.9223 info@mcaconsultants.ca
www.mcaconsultants.ca

LEGEND

- EXISTING EQUIPMENT TO BE REMOVED
- EXISTING EQUIPMENT TO REMAIN
- NEW EQUIPMENT
- C--- CONDENSATE PIPING
- ⊠ EXISTING DIFFUSER TO REMAIN
- ⊠ EXISTING TSTAT TO REMAIN
- ⊠ EXISTING TSTAT TO BE REMOVED
- ⊠ NEW PLATE SENSOR
- ⊠AD NEW ADJUSTABLE SENSOR
- IMD--- INTELLIGENT MOTORIZED DISC DAMPER
- BD--- BALANCING DAMPER
- M--- NEW MOTORIZED DAMPER



NOTE:

- ALL INTELLIGENT MOTORIZED DAMPERS (IMD) AND ASSOCIATED WIRING TO BE REMOVED.
- ALL EXISTING BASEBOARD TEMPERATURE CONTROL VALVES (TCV) TO BE REMOVED.

SECOND FLOOR PLAN HVAC DEMOLITION

1
H3/H3

SCALE: 1:50
0m 1m 2m 3m 4m 5m



| | | |
|-----------|-------------------|--------------|
| 0 | ISSUED FOR TENDER | Nov. 10 2021 |
| revisions | | date |
| project | | projet |

ARGOWAN
HVAC CONTROLS UPGRADE
CHARLOTTETOWN,
QUEENS CO., PE

drawing dessin

SECOND FLOOR PLAN HVAC DEMOLITION

| | | |
|-----------------------|---------------------------------|------------|
| designed | CED | conçu |
| date | NOVEMBER, 2021 | |
| drawn | LJDJ | dessiné |
| date | NOVEMBER, 2021 | |
| approved | CED | approuvé |
| date | NOVEMBER, 2021 | |
| Tender | | Soumission |
| PWGSC Project Manager | Administrateur de projets TPSGC | |
| project number | no. du projet | |
| | R.116036.001 | |
| drawing no. | no. du dessin | |
| | H3 of 8 | |